


Emergency PO Request

Attached PO request is for emergency (unscheduled) repair of various well components at well site 2. This site suffered a collapse of one of the pump bowls, which in turn damaged some of the upline components. This emergency service need was conveyed to senior staff in December and approved for repair at that time.

Jason Biemer

1/29/2017

A handwritten signature in black ink, appearing to be 'JB' or similar initials, written over the date.



Alsay Incorporated
6615 Gant Rd
Houston, TX 77066
Phone: (281) 444-6960
Fax: (281) 444-7081

INVOICE

INVOICE #	DATE
798	12/30/2016

RECEIVED

JAN 12 2017


Kyle Public Works

SOLD TO:

CITY OF KYLE
300 W. CENTER ST.
KYLE, TX 78640

ACCOUNT NUMBER	JOB NUMBER	PO NUMBER	PROJECT	TERMS	DUE DATE
KYLE	29915		Kyle #2	Net 30	1/29/2017

ITEM NO	QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED
	17	Hours- Mobilize to jobsite & pull pump	175.00	2,975.00
	1	Replaced bowls 10EMM-9 stage	9,308.25	9,308.25
	1	Replaced head 8 w/ 1 1/2 stuffing box	3,780.00	3,780.00
	1	New motor shaft w/ nut and key	240.00	240.00
	2	10' SS 1 1/2 shafts 10 thread left	300.00	600.00
	16	Hours- Install pump	175.00	2,800.00

City of Kyle, Texas
Approved For Payment

Signature Date 1/12/17

TOTAL AMOUNT 19,703.25

Regulated by: Texas Department of Licensing & Regulation
PO Box 12157
Austin, TX 78157

1-800-803-9202, 1-512-463-7880

Invoices Unpaid Within Terms Listed Will Be Subject To Interest Charges Of 1.5% Per Month.



PURCHASE REQUISITION FORM

VENDOR:

Alsay Incorporated - San Antonio Division
Office Manager
3359 S. E. Loop 410
San Antonio, TX 78222

REQUESTING DEPT:

Public Works
Jason Biemer
Division Manager Treatment Ops
512-262-3024 X 4012
512-749-6916

BILL TO:

City of Kyle
Public Works Department
520 E. FM 150
Kyle, TX 78640

VENDOR NO.	VENDOR PHONE NUMBER	TERMS	DATE	REQUIRED DELIVERY DATE		
	210-628-1090	30 Days	12/30/2016	1/29/2019		
SHIPPING INSTRUCTIONS						
ITEM	QTY	DESCRIPTION OF GOODS/SERVICES	BUDGET AVAIL?	ACCOUNT CODES	UNIT PRICE	AMOUNT
	1.00	Emergency Rebuild of Well Pump #2 - Bowl Failure - Dishcharge Head Failure	Yes	310-820-54152	19,703.25	19,703.25

SUBTOTAL: 19,703.25

TAX: Not Applicable 0.00

SHIPPING: 0.00

TOTAL: 19,703.25

AUTHORIZED SIGNATURE

IMPORTANT: PLEASE CHECK THAT THE BUDGET IS AVAILABLE TO MAKE THIS PURCHASE