ORDINANCE NO.	
---------------	--

AN ORDINANCE OF THE CITY OF KYLE, TEXAS, AMENDING THE ADOPTION OF THE 2015 EDITION OF THE INTERNATIONAL FIRE **PROVIDING FOR** THE AMENDMENT CODE; OF LOCAL AMENDMENTS THERETO; PROVIDING THAT THIS ORDINANCE IS CUMULATIVE OF ALL ORDINANCES; AMENDING THE CITY ORDINANCE AND THE CODE OF ORDINANCES; REPEALING ALL PARTS OF **ORDINANCES** IN **CONFLICT**; **PROVIDING** SEVERABILITY CLAUSE; PROVIDING A SAVINGS CLAUSE; PROVIDING SEVERABILITY AND OPEN MEETINGS CLAUSES; AND PROVIDING FOR RELATED MATTERS.

Whereas, the public health, safety and welfare, require the adoption and enforcement of codes governing the issuance of permits for inspection and completion of construction, plumbing, electrical and buildings within the City of Kyle, Texas; and

Whereas, the public health, safety and welfare will be served by updating certain codes heretofore adopted by the City;

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF KYLE, TEXAS:

SECTION 8.

That Section 8-32 of the Code of Ordinances of the City of Kyle, Texas, is hereby amended to read as follows;

SECTION § 8-32. AMENDMENTS.

Jennifer Vetrano, City Secretary

Section 503.2.1; change to read as follows:

503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of not less than 14 feet (4267 mm).

Exception: Vertical clearance may be reduced; provided such reduction does not impair access by fire apparatus and approved signs are installed and maintained indicating the established vertical clearance when approved.

Effective Date. This ordinance shall take effect im publication in accordance with the provisions of the	2	1 0
PASSED AND APPROVED on First Reading this	day of	, 2017.
FINALLY PASSED AND APPROVED on this	day of	, 2017.
ATTEST:	THE CITY OF KYLE, TEXAS	

R. Todd Webster, Mayor