



10/27/2005 03:04 PM

## Hays County Environmental Health NOTICE OF APPROVAL FOR ON-SITE SEWAGE FACILITY

THIS IS TO CERTIFY that the on site sewage facility located at:

OSSF #: 2005 - 1753

105 B SUNRISE DR, KYLE TX 78640

Grid:

SUNRISE ACRES

Block: Lot: 81

meets or exceeds the basic requirements established by the County.

LICENSE TO OPERATE this facility is hereby granted to the owner. This license simply grants permission to operate this facility; it does not guarantee its successful operation. Routine maintenance and proper functioning are the sole responsibility of the owner.

KEEP THIS LICENSE with important papers. You may need it when selling your house or if a malfunction occurs

Tank Type:

Valve:

Max Flow: 180 gallons/day

Tank Size: 750 gallons

Drainfield Size: 2080 sq. ft.

Installed By: VEGA, JULIO

Engineered By: CONNER, JIM

The above referenced private sewage facility has been inspected by the Hays County Health Department for compliance with the Rules of Hays County and, based on information provided in the application, has been found to comply with the requirements of those Rules.

NOTE: This certification does not extend to the materials, workmanship or fabrication of the private sewage facility so as to express or imply to the owner or installer of the facility any warranty by or rights against Hays County or any of its agencies, as to the quality or durability of the facility nor compliance with the owner's individual specifications and requirements, but solely relates to the facility meeting the requirements of Hays County in effect as of this date.

NOTE: This approval simply grants permission to operate this facility; it does not guarantee its successful operation. Routine maintenance and proper functioning are the sole responsibility of the owner.

NOTE: This approval remains in effect until such time as there is evidence that this facility is not operating properly and may constitute a threat to the health of the people of Hays County.

The specified backfill should not be altered or covered in any way except for sodded grass or grass seeded cover to promote evaporation. All plumbing in the house should be kept in good repair to minimize flooding of the drainfield.



Date of Final Inspection: 10/27/2005

Issued this date: COPY

Sanitarian

Director, Environmental Health